

Dorrigo WASTEWATER TREATMENT PLANT
Coramba Rd Dorriggo 2453

EPA Licence No. 001273
Expires 30 June 2022

IN EMERGENCY PHONE 02 6655 6073

Date of reading / sampling	Volume for period - kL	Period - days	Average daily inflow - kL	Maximum daily inflow - kL	mg/L BOD5	mg/L Total Suspended Solids	mg/L Grease and oil	mg/L Ammonia nitrogen	mg/L Total nitrogen	mg/L Total phosphorus	pH	Faecal coliforms/100mL	Dangar Falls faecal coli/100mL	COMMENTS
14/07/2021	2,700	14	193	375	<2	<2	<2	0.28	2.40	0.07	7.5	3	222	
28/07/2021	2,553	14	182	293	2	14	<2	0.18	1.77	0.14	7.6	2	2,270	
11/08/2021	2,607	14	186	349	3	4	<2	1.39	3.98	0.19	7.3	3	55	
25/08/2021	3,531	14	252	334	<2	4	<2	0.44	5.16	0.11	7.3	0	150	
8/09/2021	3,485	14	249	468	<2	3	<2	0.34	2.94	0.10	7.3	0	40	
22/09/2021	2,363	14	169	289	<2	<2	<2	0.31	2.37	0.13	7.6	0	435	
6/10/2021	2,509	14	179	292	<2	<2	<2	0.25	2.11	0.13	7.4	5	148	
20/10/2021	2,933	14	210	307	<2	<2	<2	0.31	2.69	0.09	7.4	0	1,530	
3/11/2021	2,544	14	182	360	<2	2	<2	0.27	4.77	0.17	7.4	0	180	
17/11/2021	2,862	14	204	476	<2	<2	<2	0.08	4.81	0.19	7.4	3	150	
1/12/2021	3,384	14	242	449	<2	2	<2	0.12	3.09	0.07	7.5	2	710	
15/12/2021	4,143	14	296	432	<2	<2	<2	0.16	1.74	0.17	7.4	0	90	
5/01/2022	7,488	21	357	735	<2	<2	<2	0.33	2.35	0.16	7.2	0	1,470	
19/01/2022	6,443	14	460	733	<2	2	<2	0.19	2.30	0.17	7.3	0	980	
2/02/2022	7,970	14	569	1,077	<2	<2	<2	0.18	6.59	0.19	7.2	0	345	
16/02/2022	4,899	14	350	631	<2	4	<2	0.11	1.77	0.18	7.5	0	150	
2/03/2022	10,697	14	764	2,198	<2	<2	<2	0.07	2.28	0.09	6.6	0	240	
16/03/2022	9,921	14	709	1,703	<2	<2	<2	0.04	2.40	0.17	7.3	0	585	
13/04/2022	9,300	14	664	4,136	<2	<2	<2	0.09	1.80	0.18	7.4	2	140	
21/04/2022	11,023	14	787	1,778	<2	<2	<2	0.16	1.78	0.13	7.5	0	15	
27/04/2022	5,269	14	376	585	<2	4	<2	0.06	1.84	0.10	7.6	0	135	
11/05/2022	3,746	14	268	485	<2	7	<2	0.29	1.69	0.13	7.8	0	550	
25/05/2022	4,079	14	291	666	<2	<2	<2	0.30	1.92	0.10	7.4	0	195	
8/06/2022	3,096	14	221	344	<2	10	<2	0.25	2.51	0.15	7.6	6	45	
22/06/2022	2,762	14	197	298	<2	4	<2	0.18	2.00	0.11	7.6	0	65	
29/06/2022	1,174	7	168	299	<2	4	<2	0.35	2.41	0.08	7.5	0	70	
Sample 90th p	123,481				2.90	9.40	<2	0.35	4.79	0.19	7.60	3	1,225	
Licence 90% limit					10	15	2	2	10	0.5	-	200	-	
Sample maximum				4,136	3.00	14.00	0.00	1.39	6.59	0.19	7.80	6	2,270	