

**Dorrigo WASTEWATER TREATMENT PLANT  
Coramba Rd Dorriggo 2453**

**EPA Licence No. 001273  
Expires 30 June 2023**

**IN EMERGENCY PHONE 02 6655 6073**

Date of reading / sam	Volume for period - kl	Period - days	Average daily inflow -	Maximum daily inflow	mg/L BOD5	mg/L Total Suspended	mg/L Grease and oil	mg/L Ammonia nitrogen	mg/L Total nitrogen	mg/L Total phosphorus	pH	Faecal coliforms/100	Dangar Falls faecal c
20/07/2022	4,575	20	229	713	<2	<2	<2	0.17	2.00	0.05	7.5	0	5
27/07/2022	2,170	7	310	494	<2	<2	<2	0.90	2.72	0.05	7.4	0	90
3/08/2022	1,357	7	194	332	<2	2	<2	0.17	2.24	0.09	7.4	0	90
10/08/2022	1,353	7	193	270	<2	2	<2	0.06	1.78	0.07	7.5	0	50
24/08/2022	2,652	14	189	330	<2	8	<2	0.97	3.86	0.13	7.8	1	65
7/09/2022	3,066	14	219	483	<2	2	<2	0.26	2.37	0.16	7.3	0	155
21/09/2022	2,959	14	211	352	<2	8	<2	0.09	2.06	0.11	7.6	0	15
5/10/2022	5,802	14	414	1,031	<2	9	<2	0.08	1.68	0.10	7.3	0	150
19/10/2022	3,330	14	238	342	<2	7	<2	0.39	2.37	0.22	7.4	0	75
2/11/2022	4,882	14	349	551	<2	6	<2	0.11	2.00	0.29	7.5	0	90
16/11/2022	3,321	14	237	373	4	21	<2	0.08	2.89	0.53	7.7	2	80
30/11/2022	2,819	14	201	327	<2	<2	<2	0.27	2.58	0.57	7.3	0	85
14/12/2022	3,004	14	215	370	<2	4	<2	0.10	1.97	0.21	7.3	2	135
4/01/2023	4,502	21	214	316	<2	<2	<2	0.32	2.00	0.19	7.3	0	210
18/01/2023	2,944	14	210	342	2	4	<2	0.67	3.01	0.35	7.4	18	380
1/02/2023	3,990	14	285	554	<2	15	<2	0.06	2.89	0.42	7.5	0	520
15/02/2023	2,794	14	200	307	<2	<2	<2	0.08	1.81	0.27	7.2	0	475
1/03/2023	3,416	14	244	548	4	<2	<2	1.55	3.52	0.52	7.2	0	1,100
15/03/2023	2,987	14	213	336	<2	<2	<2	0.07	2.12	0.29	7.1	0	170
29/03/2023	3,885	14	278	548	<2	16	<2	0.18	4.89	0.84	6.9	0	5,650
12/04/2023	3,591	14	257	380	2	17	<2	0.41	4.12	1.15	7.1	3	160
26/04/2023	3,369	14	241	586	<2	3	<2	0.12	3.57	0.30	7.0	0	460
10/05/2023	3,071	14	219	350	<2	<2	<2	0.13	2.42	0.14	7.4	0	290
24/05/2023	2,996	14	214	473	<2	<2	<2	0.23	2.17	0.08	7.2	87	240
7/06/2023	3,031	14	217	324	<2	<2	<2	0.29	2.18	0.06	7.1	0	170
21/06/2023	2,577	14	184	296	<2	4	<2	0.21	1.29	0.16	6.9	0	45
Sample 90th p	84,443				4.00	16.50	<2	0.79	3.72	0.55	7.55	3	502
Licence 90% limit					10	15	2	2	10	0.5	-	200	-
Sample maximum				1,031	4.00	21.00	0.00	1.55	4.89	1.15	7.80	87	5,650
Licence 100% limit				3,000	15	20	10	5	15	1	6.5-8.5	600	-
Total Volume	84,443	356	237										
	kL	days	kL /day										

COMMENTS

Notes: