

**Dorrigo WASTEWATER TREATMENT PLANT
Coramba Rd Dorrigo 2453**

**EPA Licence No. 001273
Expires 30 June 2024**

IN EMERGENCY PHONE 02 6655 6073

Date of reading / sampling	Volume for period - kL	Period - days	Average daily inflow - kL	Maximum daily inflow - kL	mg/L BOD5	mg/L Total Suspended Solids	mg/L Grease and oil	mg/L Ammonia nitrogen	mg/L Total nitrogen	mg/L Total phosphorus	pH	Faecal coliforms/100mL	Dangar Falls faecal coli/100mL	COMMENTS
5/07/2023	953	5	191	297	<2	<2	<2	0.37	1.27	0.08	7.4	0	535	
19/07/2023	2,847	14	203	288	<2	3	<2	0.28	1.90	0.17	7.2	0	142	
2/08/2023	2,599	14	186	297	2	4	<2	0.18	1.14	0.15	7.3	0	590	
16/08/2023	2,598	14	186	275	2	5	<2	0.13	1.78	0.14	7.3	0	180	
30/08/2023	2,547	14	182	353	2	7	<2	0.50	2.20	0.26	7.2	29	180	
13/09/2023	2,659	14	190	326	<2	<2	<2	0.32	1.66	0.10	7.3	3	450	
27/09/2023	2,634	14	188	394	<2	2	<2	0.33	2.07	0.08	7.3	0	90	
11/10/2023	2,504	14	179	306	<2	5	<2	0.18	2.42	0.16	7.3	2	300	
25/10/2023	2,635	14	188	364	<2	<2	<2	0.21	2.11	0.29	7.5	0	410	
8/11/2023	3,210	14	229	497	<2	<2	<2	0.47	2.96	0.71	7.4	0	420	
22/11/2023	2,601	14	186	297	<2	<2	<2	0.31	2.72	0.16	7.5	0	660	
6/12/2023	2,800	14	200	309	<2	<2	<2	0.07	1.39	0.16	7.4	0	270	
20/12/2023	5,557	28	198	333	<2	2	<2	0.23	2.23	0.17	7.3	0	260	
3/01/2024	6,847	14	489	2,245	5	9	<2	0.99	4.03	0.20	7.6	0	380	
17/01/2024	2,411	7	344	537	<2	<2	<2	0.21	2.55	0.13	7.3	0	250	
31/01/2024	1,839	7	263	370	<2	2	<2	0.40	2.00	0.22	7.4	0	260	
14/02/2024	4,686	14	335	606	<2	3	<2	0.31	3.10	0.25	7.3	2	260	
28/02/2024	4,365	14	312	460	<2	<2	<2	0.13	1.46	0.12	7.3	5	315	
13/03/2024	3,239	14	231	349	<2	<2	<2	0.16	1.82	0.14	7.5	0	260	
27/03/2024	3,305	14	236	317	<2	<2	<2	0.34	6.44	0.11	7.4	2	285	
10/04/2024	3,490	14	249	352	<2	5	<2	0.17	1.54	0.09	8.3	0	270	
24/04/2024	2,959	14	211	320	<2	4	<2	0.03	1.18	0.07	7.3	3	120	
8/05/2024	3,226	14	230	567	<2	<2	<2	0.13	2.32	0.11	7.4	8	1,325	
22/05/2024	3,995	14	285	594	<2	2	<2	1.21	3.63	0.32	7.5	0	60	
5/06/2024	3,056	14	218	387	<2	2	<2	0.42	3.32	0.28	7.6	1	55	
19/06/2024	2,603	14	186	208	<2	<2	<2	0.43	3.36	0.15	7.5	0	95	
Sample 90th p	82,165				4.10	6.40	<2	0.49	3.50	0.29	7.55	4	563	
Licence 90% limit					10	15	2	2	10	0.5	-	200	-	
Sample maximum				2,245	5.00	9.00	0.00	1.21	6.44	0.71	8.30	29	1,325	
Licence 100% limit				3,000	15	20	10	5	15	1	6.5-8.5	600	-	
Total Volume	82,165	355	231											
	kL	days	kL /day											

Notes: